



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	8165-2232:0501
CATEGORY:	8165 - VENTS FOR WILDLAND URBAN INTERFACE (W.U.I.)
LISTEE:	Brandguard Vents 6 Rancho Circle, Lake Forest, CA, 92630 Contact: Berkompas, Kelly (949) 305-8059 Email: kelly@brandguardvents.com
DESIGN:	Model FP2011 Fire Plug Vent. Model is a 2" round soffit and undereave vent constructed of 26 gauge, hot dipped, galvanized steel with a 1/16" mesh plate on the back side. Refer to manufacturer's installation instructions and product data sheets.
RATING:	Tested in accordance with ASTM E2886
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rating, and SFM label.
APPROVAL:	Listed as soffit and undereave vent for use in the Wildland Urban Interface Areas for vertical installation only. Refer to listee's Installation Instruction Manual for details.
NOTES:	

11-24-20 VWW



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/01/2024

Listing Expires: 06/30/2025

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division